



SALEMLAKES FIRE / RESCUE

Committed to serve professionally with honor, integrity, and compassion.



FIRE ALARM SYSTEM SUBMITTALS

Information Required for Submittal to be reviewed by FSCI

ALL FIRE ALARM SUBMITTALS ARE TO BE DIRECTLY SUBMITTED TO FSCI

Code sets used: Wisconsin Chapter SPS 314
I-Codes 2015

See NFPA 72 for a complete submittal list.
State plans to not satisfy the local AHJ permitting process.

- Plans must be to a reviewable scale and clearly show work to be done including a detailed scope of work.
- Submit number of complete sets of plans including cut/datasheets as required by the AHJ. (3)
- Electronic drawing set in Adobe PDF format.
- All plans must have the contractors name, address, phone number and license information.
- System designer name and qualification information (e.g. P.E. or NICET certification).
- Plans must show the job name and complete address.
- List codes and editions referenced.
- The square foot area of the building must be noted on the plans.
- A summary sheet or symbol list showing a device count shall be provided.
- Catalog cut sheets must be provided and highlighted for all components to be installed.
- Specific details must be provided regarding the offsite monitoring of the system including type of transmission means and name and location of receiving station.
- All wiring information must be shown on the plans including size, type, and all point-to-point wire runs.
- Complete battery backup calculations must be provided that clearly note battery size to be provided.
- Voltage drop calculations using the "UL MAX" values for notification appliances must be provided.

Fire prevention office contact: fpo@voslwi.org / 262-298-5635