

RESOLUTION NO. 2022.06-57

Resolution of the Village of Salem Lakes Board of Trustees, acting as the Commissioners of the Village of Salem Lakes Utility District.

The Commission of the Village of Salem Lakes Utility District having reviewed the 2021 Compliance Maintenance Annual Report for the Village of Salem Lakes Collection System and Treatment Plant which is attached hereto as Exhibit A:

NOW, THEREFORE, BE IT RESOLVED THAT;

- 1) The attached Compliance Maintenance Annual Report is hereby confirmed and approved; and
- 2) The Village of Salem Lakes Utility District shall continue to implement the adopted "Master Plan" during 2022; and
- 3) The Village Board acknowledges the 94.5 mg/kg molybdenum level in the biosolids, generated during 2021, the permit limit level is 75 mg/kg and actions taken to find sources of molybdenum in the collection system; and
- 4) The Village of Salem Lakes Utility District shall continue to be operated in its usual manner for the purpose of maintaining the effluent requirements contained in the WPDES permit.

Adopted at the regular meeting of the Board of Trustees of the Village of Salem Lakes on this date of June 13th, 2022.

Village of Salem Lakes Board of Trustees,
Kenosha County, Wisconsin,
Acting as the Commissioners of the
Village of Salem Lakes Utility District

By: Diann Tesar
Diann Tesar, President

Attest: Amanda Procknow
Amanda Procknow, Deputy Clerk